

Certificate of Product Approval

Certificate Number: 010t

Issue: 15

Apollo Fire Detectors Limited

36 Brookside Road
 Havant
 Hampshire
 PO9 1JR
 United Kingdom



is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

Orbis Multisensory Smoke Detector Range
 (refer to Appendix for details)

Standards

EN 54-7:2000 + A1:2002 + A2:2006
CEA 4021: 2003

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for LPCB

P Halligan
 Verifier

10 April 2017
 Date of Issue

01 January 2004
 Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX
 T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com



Appendix to Certificate No: 010t

Issue: 15

Apollo Fire Detectors Limited

Certified Product	Description	LPCB Ref.No.
Orbis	Multisensor Smoke Detectors with Apollo Approval Reference* 00008 (Approved For Use with Base Styles OB, OL, OD, DX, OR, EB and ORB-BA-10008-APO Adaptor Base) ORB-OH-13001-APO Orbis Multisensor Smoke Detector with SensAlert, FasTest and DirtAlert ORB-OH-13003-APO Orbis Multisensor Smoke Detector with Flashing LED, SensAlert, FasTest and DirtAlert OEX-OH-13007-APO Orbis Multisensor Smoke Detector with Flashing LED and SensAlert OEX-OH-13016-APO Orbis Multisensor Smoke Detector with SensAlert	010t/01
Orbis IS	Intrinsically Safe Multisensor Detectors with Apollo Approval Reference* 50008 (Approved For Use with Base Styles OB (+ATEX marking) and ORB-BA-50008-APO Adapter Base) ORB-OH-53027-APO Orbis Intrinsically Safe Multisensor Detector with SensAlert, FasTest and DirtAlert ORB-OH-53028-APO Orbis Intrinsically Safe Multisensor Detector with Flashing LED, SensAlert, FasTest and DirtAlert	010t/02

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for LPCB

P Halligan

Verifier

10 April 2017

Date of Issue

01 January 2004

Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com




Appendix to Certificate No: 010t

Issue: 15

Apollo Fire Detectors Limited

Bases

TimeSaver bases with Apollo Approval Reference*
OB: ORB-MB-00001-APO TimeSaver base

TimeSaver LX bases with Apollo Approval Reference*
OL: ORB-MB-00002-APO TimeSaver base LX (without continuity checking link)

TimeSaver diode bases with Apollo Approval Reference*
OD: ORB-DB-00003-APO TimeSaver diode base

TimeSaver LX diode bases with Apollo Approval Reference*
DX: OLX-DB-00007-APO TimeSaver diode base LX (without continuity checking link)

TimeSaver relay bases with Apollo Approval Reference*
OR: ORB-RB-10004-APO TimeSaver relay base

TimeSaver IS bases with Apollo Approval Reference*
OB (+ATEX marking): ORB-MB-50018-APO TimeSaver IS base

TimeSaver deep bases with Apollo Approval Reference*
EB: ORB-MB-00019-APO TimeSaver deep base

ORB-BA-50008-APO Orbis intrinsically safe adaptor base (to be used in conjunction with the following bases only: 45681-207)

ORB-BA-10008-APO Orbis adaptor base (to be used in conjunction with the following bases only: 45681-200 & 45681-201)

* The Apollo 'Approval Reference Number' identifies a group of detectors that all have the same physical construction, but have features enabled or disabled via their software, and/or regional marking variations.

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for LPCB

P Halligan

Verifier

10 April 2017

Date of Issue

01 January 2004

Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com



Appendix to Certificate No: 010t

Issue: 15

Apollo Fire Detectors Limited

Alternative Model No./Label

LPCB Ref No.	Model No.	Alternative Model No./Label	Cross-listed company	Cross-Listed Co Cert./ Ref No.
010t/01	ORB-OH-13001-APO	ORB-OH-13001-AMP	AMPAC Technologies PTY Ltd	010t/01
010t/01	ORB-OH-13001-APO	FAPO-MUS	Emergi-Lite Safety Systems (Thomas & Betts Ltd)	010t/01
010t/01	ORB-OH-13001-APO	ORB-OH-13001-ADV	Advanced Electronics Limited	010t/01
010t/01	ORB-OH-13001-APO	EDC-30	Schneider Electric Fire & Security Oy	010t/01
010t/01	ORB-OH-13003-APO	ORB-OH-13003-AMP	AMPAC Technologies PTY Ltd	010t/01

Bases

LPCB Ref No.	Model No.	Model No./Label	Cross-listed company	Cross-Listed Co Cert./ Ref No.
010	ORB-MB-00001-APO	ORB-MB-00001-AMP	AMPAC Technologies PTY Ltd	010
010	ORB-MB-00001-APO	FAPO-TSB	Emergi-Lite Safety Systems (Thomas & Betts Ltd)	010
010	ORB-MB-00001-APO	EBC-10	Schneider Electric Fire & Security Oy	010
010	ORB-MB-00002-APO	ORB-MB-00002-AMP	AMPAC Technologies PTY Ltd	010
010	ORB-DB-00003-APO	ORB-DB-00003-AMP	AMPAC Technologies PTY Ltd	010
010	ORB-DB-00003-APO	FAPO-TDB	Emergi-Lite Safety Systems (Thomas & Betts Ltd)	010
010	ORB-RB-10004-APO	ORB-RB-10004-AMP	AMPAC Technologies PTY Ltd	010
010	ORB-RB-10004-APO	FAPO-TRB	Emergi-Lite Safety Systems (Thomas & Betts Ltd)	010

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

P. Halligan

Signed for LPCB

P Halligan

Verifier

10 April 2017

Date of Issue

01 January 2004

Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com



Appendix to Certificate No: 010t

Issue: 15

Apollo Fire Detectors Limited

LPCB Ref No.	Model No.	Model No./Label	Cross-listed company	Cross-Listed Co Cert./ Ref No.
010	ORB-RB-10004-APO	EBC-20	Schneider Electric Fire & Security Oy	010
010	ORB-MB-00019-APO	EBC-11	Schneider Electric Fire & Security Oy	010

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for LPCB

P Halligan

Verifier

10 April 2017

Date of Issue

01 January 2004

Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com


